

**REQUEST FOR QUOTATION
(THIS IS NOT AN ORDER)**

THIS RFO IS IS NOT A SMALL BUSINESS SET-ASIDE

PAGE OF PAGES
1 11

1. REQUEST NO. N00173-13-Q-0075	2. DATE ISSUED 01/11/2013	3. REQUISITION/PURCHASE REQUEST NO. 55-9002-13	4. CERT. FOR NAT. DEF. UNDER BDSA REG. 2 AND/OR DMS REG. 1 RATING
5a. ISSUED BY Supply Officer (Code 3410) NRL Washington DC 20375			6. DELIVER BY (Date) 02/21/2013
5b. FOR INFORMATION CALL (NO COLLECT CALLS)			7. DELIVERY <input checked="" type="checkbox"/> FOB DESTINATION <input type="checkbox"/> OTHER (See Schedule)
NAME Donna Speight		TELEPHONE NUMBER AREA CODE NUMBER 202 767-0105	
8. TO: a. NAME ALL QUOTERS		b. COMPANY Naval Research Laboratory	
c. STREET ADDRESS		b. STREET ADDRESS 4555 Overlook Ave SW	
d. CITY		c. CITY Washington	
e. STATE		d. STATE DC	
f. ZIP CODE		e. ZIP CODE 20375	

10. PLEASE FURNISH QUOTATIONS TO THE ISSUING OFFICE IN BLOCK 5a ON OR BEFORE CLOSE OF BUSINESS (Date)
01/22/2013

IMPORTANT: This is a request for information, and quotations furnished are not officers. If you are unable to quote, please so indicate on this form and return it to the address in Block 5a. This request does not commit the Government to pay any costs incurred in the preparation of the submission of this quotation or to contract for supplies or service. Supplies are of domestic origin unless otherwise indicated by quoter. Any representations and/or certifications attached to this Request for Quotation must be completed by the quoter.

11. SCHEDULE (Include applicable Federal, State and local taxes)

ITEM NO. (a)	SUPPLIES/ SERVICES (b)	QUANTITY (c)	UNIT (d)	UNIT PRICE (e)	AMOUNT (f)
	See Attached Continuation Sheets				

12. DISCOUNT FOR PROMPT PAYMENT a. 10 CALENDAR DAYS (%) b. 20 CALENDAR DAYS (%) c. 30 CALENDAR DAYS (%) d. CALENDAR DAYS

NUMBER	PERCENTAGE
--------	------------

NOTE: Additional provisions and representations are are not attached.

13. NAME AND ADDRESS OF QUOTER		14. SIGNATURE OF PERSON AUTHORIZED TO SIGN QUOTATION	15. DATE OF QUOTATION
a. NAME OF QUOTER			
b. STREET ADDRESS		16. SIGNER	
c. COUNTY		a. NAME (Type or print)	b. TELEPHONE
d. CITY		AREA CODE	
e. STATE	f. ZIP CODE	c. TITLE (Type or print)	NUMBER

STANDARD FORM 36 JULY 1966 GENERAL SERVICES ADMINISTRATION FED. PROC. REG. (41 CFR) 1-16.101		CONTINUATION SHEET		REF. NO. OF DOC. BEING CONT'D		PAGE OF	
				N00173-13-Q-0075		2 11	
NAME OF OFFEROR CONTRACTOR							
ALL QUOTERS							
ITEM NO.	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT		
0001	<p>20 Ton Liebert CW114DCSA3</p> <p>The following specifications are necessary to meet our minimum request. Provide and install one (1) 20 ton Liebert CW114DCSA3, 460 volts, 60Hz, 5000amps rms short circuit, current rating 3 Phase Precision Cooling System normal 114 kw Chilled Water System to include:</p> <p>Insulated chilled water piping 3 way modulating control valve iCOM control with small display Display language in English Audible and visual alarms. Premium efficiency motor (7.5HP) STD.-8900 CFM fan with 0.2 external Static Pressure. Electric Reheat Reheat lockout Infrared humidifier Humidifier lockout Non-locking disconnect switch Smoke sensor with unit alarm and shutdown. Includes supervision contacts. MERV8 filter package Low voltage terminal package include: Qty (2) extra sets of remote shutdown terminals Qty (2) extra sets of common alarm terminals Main fan auxiliary switch, one set of normally open contacts. 15" high floor stand Turning vanes Main fan overload alarm. Qty-1 LT410 point leak detection sensor Qty-1 LT460-Z35, zone leak detection kit w/35 foot cable Main color: IBM charcoal (z-0420), accent color: IBM charcoal (Z-0420). Supply air temperature sensor and wiring harness.</p>	1	EA				

CONTINUATION SHEET

N00173-13-Q-0075

2 a 11

NAME OF OFFEROR CONTRACTOR

ALL QUOTERS

ITEM NO.	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001	<p>Disconnect existing electrical feed from the existing Liebert unit.</p> <p>Disconnect the existing chilled water piping from the existing unit and remove piping that makes a loop.</p> <p>Disconnect the existing humidifier piping from the unit.</p> <p>Remove and dispose of existing Liebert unit.</p> <p>Disconnect the existing ductwork from the existing chilled water unit</p> <p>Rig the new unit on to the new floor stand.</p> <p>Provide and install new piping from the existing main chilled water pipe increasing the size of the pipe and run the piping in a new direction from above to the new unit.</p> <p>Provide and install one new strainer in the chilled water supply piping.</p> <p>Provide and install one balancing valve in the chilled water return piping.</p> <p>Provide and install new thermometers and gauges on both the supply and return piping.</p> <p>Provide and install drains on both chilled water supply and return piping.</p> <p>Provide and install piping to the existing taps on the chilled water piping above the unit.</p> <p>Provide and install new chilled water valves at the main connection and at the unit for servicing.</p> <p>Provide and install insulation on the new piping including replacing insulation that was disturbed during the replacement.</p> <p>Provide and install new humidifier piping to the humidifier in the new unit.</p> <p>Provide and install new duct transitions for the supply ductwork and the return duct work.</p>				

CONTINUATION SHEET

REF. NO. OF DOC. BEING CONT'D

PAGE OF

N00173-13-Q-0075

2 b 11

NAME OF OFFEROR CONTRACTOR

ALL QUOTERS

ITEM NO.	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
----------	-------------------	----------	------	------------	--------

0001

Provide and install new 480V electrical wire for a new circuit sized correctly for the new 20 ton unit with the infrared humidifier and reheat.

Provide and install a supply temperature sensor and wire harness that will allow the supply temperature to be changed through the microprocessor iCOM.

Provide and install point leak sensor for new unit.

Provide a factory authorized start up for the new unit.

Provide a one-year warranty on labor and materials.

Provide a manufacture's equipment warranty.

Brand name or Equal

If available please include a published price list or a cost breakdown and return the RFQ package to the following fax number (202) 767-6678.

Any questions concerning this Request for Quotation (RFQ) must be emailed to SolQnA@nrl.navy.mil at least five (5) days before the closing date shown in block 10 on page 1 of the RFQ.

NAME OF OFFEROR CONTRACTOR

All Quoters

ITEM NO.	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	<p>REQUEST FOR JOB SITE VISIT DATE: 1-16-13 TIME: 10:00 a.m. Place: NAVAL RESEARCH LABORATORY 4555 Overlook Avenue, SW, Washington, DC 20375-5329 POINT OF CONTACT: Donna Speight, (202) 767- 0105 Bldg. 32 Rm. 213</p> <p>Contractors are required to VISIT the JOB SITE before any quotations are accepted for the acquisition listed on the RFQ/Solicitaion. PROPER ID is REQUIRED. A VALID Drivers License is sufficient. You are required to report to BLDG. 72 for a proper pass to access NRL. If a vendor representative does not attend the scheduled job site visit, they may be considered "Non-Responsive". At the end of the job site visit, each representative will be informed of the date quotation must be submitted. If quotations are not received by that date, they will be considered a "No Bid". Contact with the Enduser is strictly prohibited (other than the job site visit). Any contact may result in the bid being considered "tainted" and subsequently cancelled.</p> <p>Any questions the vendor representatives may have after the job site visit must be directed to the Contracting Officer (above) at email address SolQnA@labmis.nrl.navy.mil no later than 1-18-13 at 4:00 p.m. Eastern standard Time. Any changes in the description, specifications or drawings after the job site visit will be issued to ALL vendors.</p> <p>If an emergency arises and the vendor representative cannot attend the scheduled job site visit, PLEASE call the POC at the above number by the morning of the job site visit to let him/her know you will not be able to attend. The contractor is required to notify the Contracting Officer by 1-15-13, 4:00 pm of intent to attend the site visit.</p>				