

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE
PAGE 1 OF 3 PAGES

2. AMENDMENT/MODIFICATION NO. P00001
3. EFFECTIVE DATE 07/13/15
4. REQUISITION/PURCHASE REQ. NO. 67-0015-15
5. PROJECT NO. (If applicable)

6. ISSUED BY CODE
7. ADMINISTERED BY (If other than Item 6) CODE
Naval Research Laboratory
4555 Overlook Ave SW
Washington DC 30375

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)
ALL QUOTERS
(X) 9A. AMENDMENT OF SOLICITATION NO. N00173-15-Q-0323
9B. DATED (SEE ITEM 11)
10A. MODIFICATION OF CONTRACT/ORDER NO.
10B. DATED (SEE ITEM 11)
CODE FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Quotes are due 27 July 15, at 2:00pm.

See attached Continuation Sheets 2 and 2a for Questions and Answers

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Paul Gilroy Contracting Officer
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED
(Signature of person authorized to sign)	16B. UNITED STATES OF AMERICA <i>Paul P. Gilroy</i> (Signature of Contracting Officer)
	16C. DATE SIGNED 7-10-15

NAME OF OFFEROR CONTRACTOR
 ALL QUOTERS

ITEM NO.	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	<p>Q: Is there any demo that needs to be performed? A: No</p> <p>Q: Does the contractor need to provide any necessary lift equipment, unloading of shipped materials, and/or refuse containers? A: No</p> <p>Q: Are cost saving options such as return air chases vs. the double wall system desired? A: Yes</p> <p>Q: Can a drawing layout of the existing area and how the new cleanroom sits in relation be provided? A: The government does not have a drawing layout of the existing area.</p> <p>Q: Where is the required fresh air for make-up air going to come from? Just the surrounding area? A: The surrounding area.</p> <p>Q: All electrical points of connections for the cleanroom for the owner to tie into are to be by J-boxes and disconnects? No subpanels? A: No subpanels, just outlets.</p> <p>Q: Does the room need to be certified once complete by the contractor? A: No.</p> <p>Q: Please confirm. For the HVAC, no humidity control, strictly comfort cooling only? A: HVAC will be used to control both temperature and humidity. A 10 ton unit is needed and the Government will set it up.</p> <p>Q: Do you have a sketch or drawing? A: No</p> <p>Q: The spec references a Polypropylene core for the walls, standard is Polystyrene - is polystyrene acceptable? A: Yes</p>				

CONTINUATION SHEET

N00173-15-Q-0323

2 a 3

NAME OF OFFEROR CONTRACTOR

ALL QUOTERS

ITEM NO.	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
	<p>Q: Is the gown room located within the 14'x27' enclosure or outside of the structure? A: Is it inside.</p> <p>Q: What is the required cleanroom wall thickness? Assuming this is a free-standing structure. A: No specific requirement. It must be a modular framed free-standing structure.</p> <p>Q: The spec requests (2) 44"W doors, is 48" or 36" acceptable? A: Yes</p> <p>Q: Are any electrical outlets required, A: Yes, 10 standard outlets inside the clean room are needed.</p>				